

2021 JUN 23 AM 9:31



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION**Consumer Confidence Report (CCR)***City of Carthage*

Public Water System Name

0400001

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bills (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other _____	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U. S. Postal Mail	
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input checked="" type="checkbox"/> Posted in public places (attach list of locations)	
<input checked="" type="checkbox"/> Posted online at the following address (Provide Direct URL): <u>https://msrwa.org/2020ccr/carthage.pdf</u>	

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Dale EDGAR
Name

operator
Title

6/22/21
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)

Email: water.reports@msdh.ms.gov

MSDH, Bureau of Public Water Supply

Fax: (601) 576-7800

(NOT PREFERRED)

P.O. Box 1700

Jackson, MS 39215

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2020 Annual Drinking Water Quality Report
City of Carthage - PWS#:0400001
June 2021

2021 JUN 10 AM 9:54

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing from the Meridian Upper Wilcox Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Carthage have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Robert D. Edgar at 601.540.7795. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at 6:00 PM at the City Hall Board Room, 212 West Main Street, Carthage, MS 39051.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2019*	.01	.0094 - .01	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019*	1.7	1.6 – 1.7	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2016/18*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2019*	.318	.266 – .318	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

17. Lead	N	2016/18*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	62000	56000 - 62000	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2020	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2020	9.9	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1	.9 – 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2020.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6 - 1.2 mg/l

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our water system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 92%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Carthage works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

ACCOUNT NO.	SERVICE FROM	SERVICE TO
090001112	05/01	06/01
SERVICE ADDRESS		
101 ALENA DR		
CURRENT	METER READINGS PREVIOUS	USED
6187	6123	64
CHARGE FOR SERVICES		

WTR	21.70
SWR	21.70
GRB	15.16
NET DUE >>>	58.56
SAVE THIS >>	8.68
TOTAL DUE >>	67.24

RETURN THIS STUB WITH PAYMENT TO:

CITY OF CARTHAGE
212 MAIN STREET
CARTHAGE, MS 39051

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 52
CARTHAGE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT	SAVE THIS	GROSS AMOUNT
58.56	8.68	67.24

FOR ONLINE PAYMENTS, GO TO www.carthageutility.com.

RETURN SERVICE REQUESTED

090001112
PEAPLINE BROOKS

101 ALENA DR
CARTHAGE, MS 39051-4442



IMPORTANT NOTICE -
PAYMENT DUE BY 10TH OF MONTH

TREE AND LIMB CONTRACTORS MUST

PLEASE MAKE CHECKS PAYABLE TO:

CITY OF CARTHAGE
212 MAIN STREET
CARTHAGE, MS 39051

BUSINESS HOURS:
MONDAY - FRIDAY / 8 A.M. TO 5 P.M.

BUSINESS OFFICE TELEPHONE:
601-267-8322

Important Information about your drinking
water is available in the 2021 Consumer
Confidence Report at:

<https://msrwa.org/2020ccr/carthage.pdf>. You may
request a hard copy by checking this box ☐
or by calling our office at (601) 267-8322.

OR YOUR CONVENIENCE
NIGHT DEPOSIT SERVICE
IS AVAILABLE AT THE
ENTRANCE TO CITY HALL

ASSURE PROPER CREDIT
RETURN THIS STUB
WITH YOUR PAYMENT

THANK YOU

ACCOUNT NO.	SERVICE FROM	SERVICE TO
063462002	05/01	06/01
SERVICE ADDRESS		
400 ALLENWOOD DR		
CURRENT	METER READINGS PREVIOUS	USED
6407	6384	23
CHARGE FOR SERVICES		

RETURN THIS STUB WITH PAYMENT TO:

CITY OF CARTHAGE
212 MAIN STREET
CARTHAGE, MS 39051

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 52
CARTHAGE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT	SAVE THIS	GROSS AMOUNT
23.00	4.60	27.60

FOR ONLINE PAYMENTS, GO TO
www.carthageutility.com

RETURN SERVICE REQUESTED

063462002
SHATWANA DOMINQUE BROWN

400 ALLENWOOD DR APT 3
CARTHAGE MS 39051-4082



WTR 11.50
SWR 11.50
NET DUE >>> 23.00
SAVE THIS >> 4.60
TOTAL DUE >> 27.60

IMPORTANT NOTICE -
PAYMENT DUE BY 10TH OF MONTH

TREE AND LIMB CONTRACTORS MUST
HAUL AWAY ALL DEBRIS.

BILL MUST BE PAID IN FULL BY THE
20TH OF EACH MONTH TO AVOID
WATER BEING CUT OFF AND A
\$50.00 PENALTY ADDED TO HAVE

Important Information about your drinking water is
available in the 2021 Consumer Confidence Report at:
<https://msrwa.org/2020ccr/carthage.pdf>. You may
request a hard copy by checking this box ☐ or by calling
our office at (601) 267-8322.

PLEASE MAKE CHECKS PAYABLE TO:

CITY OF CARTHAGE
212 MAIN STREET
CARTHAGE, MS 39051

BUSINESS HOURS:
MONDAY - FRIDAY / 8 A.M. TO 5 P.M.

BUSINESS OFFICE TELEPHONE:
601-267-8322

FOR YOUR CONVENIENCE
NIGHT DEPOSIT SERVICE
IS AVAILABLE AT THE
ENTRANCE TO CITY HALL

**IF PROPER CREDIT
ON THIS STUB
(OUR PAYMENT)**

THANK YOU

ACCOUNT NO.	SERVICE FROM	SERVICE TO
063462019	05/01	06/01
SERVICE ADDRESS		
400 ALLENWOOD DR		
CURRENT	METER READINGS PREVIOUS	USED
8393	8391	2
CHARGE FOR SERVICES		

RETURN THIS STUB WITH PAYMENT TO:

CITY OF CARTHAGE
212 MAIN STREET
CARTHAGE, MS 39051

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 52
CARTHAGE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT	SAVE THIS	GROSS AMOUNT
23.00	4.60	27.60

FOR ONLINE PAYMENTS, GO TO
www.carthageutility.com

RETURN SERVICE REQUESTED

063462019
SHAMERIA LEAVY

400 ALLENWOOD DR APT 4
CARTHAGE, MS 39051-4082



WTR 11.50
SWR 11.50
NET DUE >>> 23.00
SAVE THIS >> 4.60
TOTAL DUE >> 27.60

IMPORTANT NOTICE -
PAYMENT DUE BY 10TH OF MONTH

TREE AND LIMB CONTRACTORS MUST
HAUL AWAY ALL DEBRIS.

BILL MUST BE PAID IN FULL BY THE
20TH OF EACH MONTH TO AVOID
WATER BEING CUT OFF AND A
\$50.00 PENALTY ADDED TO HAVE

Important Information about your drinking water is
available in the 2021 Consumer Confidence Report at:
<https://msrwa.org/2020ccr/carthage.pdf>. You may
request a hard copy by checking this box ☐ or by calling
our office at (601) 267-8322.

PLEASE MAKE CHECKS PAYABLE TO:

CITY OF CARTHAGE
212 MAIN STREET
CARTHAGE, MS 39051

BUSINESS HOURS:
MONDAY - FRIDAY / 8 A.M. TO 5 P.M.

BUSINESS OFFICE TELEPHONE:
601-267-8322

FOR YOUR CONVENIENCE
NIGHT DEPOSIT SERVICE
IS AVAILABLE AT THE
ENTRANCE TO CITY HALL

RE PROPER CREDIT
URN THIS STUB
YOUR PAYMENT

THANK YOU

*Ward 1 Alderman ~ Miracle Matlock
Ward 2 Alderman ~ David Cocroft*



*Ward 3 Alderman ~ Laurie Henderson
Ward 4 Alderman ~ David Herrington*

City of Carthage

Mary Ann Vivians, Mayor

2020 CCR posted at following places:

Carthage City Hall
212 W Main St
Carthage, MS 39051

Carthage Police Department
302 W Main St
Carthage, MS 39051

Carthage-Leake County Library
14 E Franklin St
Carthage, MS 39051